

Annual Drinking Water Quality Report

The Water We Drink

Akron Water ~ July 1, 2026

We are pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from 2 deep gravel packed wells.

We have a source water assessment plan available from our office that provides more information such as potential sources of contamination. I'm pleased to report that our drinking water is safe and meets federal and state requirements.

This report shows our water quality and what it means.

We want our valued customers to be informed about their water utility. If you have any questions about this report or concerning your water utility, please contact Jake Gearhart at 574-893-4123. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 3rd Monday of each

month at 6:00 p.m. at Town Hall, 206 West Rochester St. Akron, IN.

Akron Water Department routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring from the period of January 1 to December 31, 2025. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the

Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

The sources of drinking water (both tap water and bottled waters) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As the water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- (B) Inorganic contaminants such as salts and metals, which can be naturally-occurring or the result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile

organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff and septic systems.

- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact us at 574-893-4123.

Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These

people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on the appropriate means to lessen the risk of infections by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead: Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Akron Water Department is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposure. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or

making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Akron Water Department at 574-893-4123. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

TTHM(Total Trihalomethanes) Some people who drink water containing trihalometanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of cancer.

Wellhead Protection

The Akron Water Works has implemented a State-approved Wellhead Protection Program to minimize the risk of contamination to the groundwater pumped by our wells. By identifying potential sources of contamination, working to prevent spills, and preparing a contingency plan to be used in the event of contamination, the Water Works helps ensure the safety of your drinking water. If you would like to learn more about Akron's Wellhead Protection Program, please contact our office.

Please call our office if you have questions. 574-893-4123

Lead Service Line Inventory (LSLI)

To view Akron's LSLI, please visit: <https://pws-ptd.120wateraudit.com/AkronWD-IN>

KEY TO TABLE

AL=Action Level
MCL=Maximum Contaminant Level
MCLG=Maximum Contaminant Level Goal
MRDLG=Maximum Residual Disinfection Level Goal
MRDL=Maximum Residual Disinfection Level
na=not applicable
ppm=parts per million, or milligrams per liter (mg/L)
ppb=parts per billion, or micrograms per liter (ug/L)
pCi/L=picocuries per liter, a measure for radiation

In this table, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we have provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Maximum Residual Disinfection Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfection is necessary for control of microbial contaminants.

Detected Level: The highest level detected of a contaminant for comparison against the acceptance levels for each parameter. These levels could be the highest single measurement, or an average of values depending on the contaminant.

Range: The lowest to the highest values for all samples tested for each contaminant. If only one sample is tested, or no range is required for this report, then no range is listed for that contaminant in the table.

Average (Avg): Regulatory compliance with some MCLs are based on running annual average of monthly samples.

“We Count Every Drop”



WATER-QUALITY DATA TABLE

DISINFECTANT AND DISINFECTANT BY-PRODUCTS		COLLECTION DATE	HIGHEST LEVEL DETECTED	RANGE OF LEVELS DETECTED	MCLG	MCL	UNITS	VIOLATION	LIKELY SOURCES
Chlorine		2025	1	1-1	MRDLG=4	MRDL=4	ppm	N	Water additive used to control microbes.
Haloacetic Acid (HAA5)		2025	57	57.1	No Goal	60	ppb	N	By-product of drinking water disinfection.
Total Teihalomethanes (TTHM)		2025	38	38	No Goal	80	ppb	N	By-product of drinking water disinfection.
INORGANIC CONTAMINANTS		COLLECTION DATE	HIGHEST LEVEL DETECTED	RANGE OF LEVELS DETECTED	MCLG	MCL	UNITS	VIOLATION	LIKELY SOURCES
Fluoride		2024	0.434	0.434	4	4	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium		2024	0.414	0.414	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
RADIOACTIVE CONTAMINANTS		COLLECTION DATE	HIGHEST LEVEL DETECTED	RANGE OF LEVELS DETECTED	MCLG	MCL	UNITS	VIOLATION	LIKELY SOURCES
Combined Radium 226/228		2020	.98	0.98-0.98	0	5	pCi/L	N	Erosion of natural deposits
Gross Alpha excluding Radon & Uranium		2020	2.2	2.2-2.2	0	15	pCi/L	N	Erosion of natural deposits
Radium-226		2020	0.41	0.41	0	5	pCi/L	N	Erosion of natural deposits
Radium-228		2020	0.57	0.57	0	5	pCi/L	N	Erosion of natural deposits
LEAD AND COPPER		COLLECTION DATE	MCLG	ACTION LEVEL	90 TH PERCENTILE	# SITES OVER AL	UNITS	VIOLATION	LIKELY SOURCES
Cooper		2023	1	1.3	0.559	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead		2023	0	15	1.08	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits

VIOLATIONS: During the period covered by this report we had the noted violations: CCR Certification Form to the State was not delivered by October 1, 2025. However, the internal records show the form was mailed to IDEM on June 5, 2025 and was never received by their office, so that's why we received the violation. The form was resent via email on October 7, 2025.